

SENTRY

4 CIRCUIT 16A DIN RAIL MOUNTED EMERGENCY LIGHTING TEST SWITCH

Presented in a compact, DIN-mountable form factor for easy installation in a switchboard, Sentry simulates mains failure for a 90 or 120 minute duration via a user-selectable switch.

In accordance with AS2293.2, manual discharge facilities for emergency lighting installations must be key-operated and automatically reverts back to its normal state upon completion of the discharge test. A 120 minute commissioning test shall be conducted for all new installations (the first discharge), followed by a 90 minute in-service discharge test every 6 months thereafter.

